## VENTAFLEX® air duct in the hygiene sector

Tightness and smooth surfaces at air duct systems

- an inseparable couple for clean air





Indoor installation:
Clean air for a production hall for
hygienic packaging.
Total volume of 110.000 m³,
spread over 400 m ducts

#### Application areas for hygienic air supply with VENTAFLEX® air ducts:

#### **Food industry**

- Bakery business
- Meat-processing industry
- Dairies
- Breweries
- Beverage manufacturers

#### **Public areas**

- Rehabilitation clinics
- Social facilities
- Retirement homes
- Swimming pools
- Sports facilities

#### **Production plants**

- Laboratories and institutions
- High Tech industry
- Engineering
- Chemical industry
- Pharmaceutical industry

Installation on an outdoor hall roof: Fresh air for meat- processing in the Netherlands Volume: 50.000 m³, spread over more than 100 m ducts



A large number of large-scale projects were realized with insulated VENTAFLEX® air duct systems in the last decades.

Our experienced team would like to support you with your ventilation concept.

### Clean air

#### in sensitive areas

In many hygienic-relevant sectors, like the food industry, rehabiltation clinics or swimming pools, hygiene plays a very special role.

The VENTAFLEX® insulated air ducts have clean room character due to their material characteristics. They meet highest hygienic demands and are certified for this.

VENTAFLEX® air ducts have a clean, smooth and discreet appearance. The smooth surfaces avoid adhesions, are easy to clean and minimize the friction losses for a hygienic air flow.

Please note: VENTAFLEX® offers special supplies for the installation in the hygiene sector.



# Active climate protection

#### due to tightness VENTAFLEX® air ducts

Climate protection is one of the big issues of this time. One important aspect here are possible energy savings potentials.

At the VENTAFLEX® air ducts a number of effects are inseparably linked: Ideal hygiene characteristics and effectiveness of the system guarantee an economical operation which complies with the strict requirements – and this with a good environmental conscience.

#### Avoid germ development ...

According to VDI 6022 page 1 the avoidance of leakage as well as the prevention of unplanned moisture due to entry or condensation is relevant for the supply air quality. All ducts are to be planned and carried out so that an unintentional admixture of air is avoided. The tighter a duct system is, the more hygenic the air guidance and therefore the supplied air is.

#### ... and save energy

At the same time tightness is one of the most important aspects when dealing with energy efficiency. For installations with high demands on energy efficiency and hygiene the tightness class ATC 2 (former D) is applied.

### The right decision for a good climate: the VENTAFLEX® system

VENTAFLEX® air ducts exceed the requirements of tightness class ATC 2 by far – without any additional measures.

Because of the application of VENTAFLEX® air ducts a leakage of a air conduction system can be reduced up to 99 % compared to conventional systems. Moreover less fan output is needed at a tight air conduction system, which leads to long-term savings of energy and thus operating costs.







#### Certified for the hygiene sector

INSTITUT FÜR LUFTHYGIENE
1144 - LOFT HADDEREN DER DER MEN Sanierungskonzente

Geprüftes Baumuster

Prüfdatum |-ort

Prüfingenieur

prüfkriterien

Prüfergebnis

Gültigkeitszeitraum

Registriernumme

Auftraggeber | Hersteller

Befor marketing VENTAFLEX® products have to meet extensive test. After going through different in-house test procedures, independant institutes are assigned to test the ducts on highest quality demands. Again it is the special characteristics of the VENTAFLEX® air ducts that allow a certification in the hygiene sector. Now also "signed and sealed".

Zertifikat

siehe Anlage 1

Hygiene – Konformitätsprüfung

Berlin, Deutschland

nygjenerelevanten Amorderunge markierten Regelwerke geprüft:

VDI 6022, Blatt 1 (07/20011) SWKI VA104-01 (04/2006)

VDI 3803 Blatt 1 (02/2010)

ONORM H 6021 (09/2003) DIN EN 13779 (09/2007)

HKP 08/14 - 04

5 Jahre: 12.2015 - 12.2020

1 Zugner

für

ausgestellt am 02.02.2016, Berlin

mitatsprüfung (HKP) herar

Allgemeine Raumlufttechnik

ILH BERLIN INSTITUT FÜR LUFTHYGIENE Zertifikat Hygiene – Konformitätsprüfung Bogenstück - Luftkanal rund mit Verbindungseleme VENTAFLEX Vertriebsgesellschaft mbH & Co. KG, Im Gewerbegebier 3, 45612 Horstmar 16.12.2015, Institut für Lufthygiene, Kurfürstenstraße 131, 10785 Berlin Deutschland siehe Anlage 1 VENTAFLEX Vertriebsgeseilschaft Gewerbegebiet 3, 48612 Horstmar Geprüftes Baumuster Dipl. Ing. (FH) Jacob Kornack, V. Zügner M.Sc. Im Rahmen der Hygiene-Konformitätsprüfung wurden die hvolenerieranten Anfreden innens der nachfestenend mit Auftraggeber | Hersteller Im Rahmen der Hygiene-Konformitätsprüfung wurden die hygienerelevanten Anforderungen" der nachfolgend mit "v" morkinsten Danabusrko senaridi. Berlin, Deutschland Prüfdatum |-ort nygjenerelevanten Amtorcærunge markierten Regelwerke geprüft: Prüfingenieur Allgemeine Raumlufttechnik Prüfkriterien VDI 6022, Blatt 1 (07/2011) ILH BERLIN SWKI VA104-01 (04/2006) DIN EN 13779 (IMPZUUT)
Die Konformität des geprüften Gerätes mit den hygiene
John Anforderungen der n. g. Regelwerke wird bestä VDI 3803 Blatt 1 (02/2010) Die Konformität des geprüften Gerätes mit den hygienerele-vanten Anforderungen der o.g. Regelwerke wird bestätigt. ONORM H 6021 (09/2003) DIN EN 13779 (09/2007) 5 Jahre: 12.2015 - 12.2020 Prüfergebnis HKP 08/14 - 03 Gerades Stück - Luftkanal rund mit Verbindungselementen siehe Anlane 1 Gültigkeitszeitraum Registriernum VENTAFLEX Vertriebsgesellschaft mbH & Co. KG, Im Gewerbegebiet 3, 48612 Horstmar 16.12.2015, Institut für Lufthyglene, Kurfürstenstraße 131, 10785 Berlin. Deutschland ausgestellt am 02.02.2016, Dipl. Ing. (FH) Jacob Kornack, V. Zügner M.Sc. Im Rahmen der Hygiene-Konformitätsprüfung wurden die hunsenerelauanten Anforden innens der nachfolgend mit Aussienerelauanten Anforden innens der nachfolgend mit Im Rahmen der Hygiene-Konformitätsprüfung wurden die hygienerelevanten Anforderungen\* der nachfolgend mit "

hygienerelevanten Anforderungen\*.

markierten Bernehmerke nannife. DIN EN 10/19 (USECULE)

Die Konformität des geprüften Gerätes mit den hygiel

Venten Anforderunnen der n. Reneilwerke wird hes Die Konformität des geprüften Gerätes mit den hygienerele vanten Anforderungen der o.g. Regelwerke wird bestätigt. **VENTAFLEX GmbH & Co. KG** Siemensstraße 46 D-48341 Altenberge

Fon +49 (0) 2505 - 938290

info@ventaflex.de www.ventaflex.de

Fax +49 (0) 2505 - 93829 -10

# VENTAFLEX® Hygiene sector Supplies-system



Matched and certified for hygiene applications according to VDI 6022







VentaFit-6022 was checked on the requirements on microbial inertness from the VDI 6022 and is certified for it — exactly like our air ducts.

Quantity	Item no.	Price €/per piece	
400 ml	0030015001	16,00	

Price group 5

#### **Material requirements**

The required amount of glue depends on the number of connection points – and of course on the diameter or rather the form of the duct. On the basis of the chart the expected quantity can be calculated, which can be produced by one bag.



Especially for tubular bags with 400 ml or 600 ml

Quantity	Item no.	Price €/per piece	
1	0030019001	54,00	

Price group 5

#### Hygiene protective packaging

Upon request our products can additionally be packaged with special VDI-conform self-adhesive foil. You receive the costs for this hygiene packagaging upon request.



Series oval	Inside dimension oval	Number of adhesion- or rather connection points, which can be produced with one tubular bag		Series round
		oval	round	
500	520/770	2	7	250
	520/1020	2		
	520/1270	1		
	520/1520	1		
630	650/900	2	5	400
	650/1150	1		
	650/1400	1		
	650/1650	0,75		
710	730/980	1	4	500
	730/1230	1		
	730/1480	0,75		
	730/1730	0,75		
800	820/1070	1	3	630
	820/1320	0,75		
	820/1570	0,75		
	820/1820	0,5		
900	920/1170	0,75	2	800
	920/1420	0,75		
	920/1670	0,5		
	920/1920	0,5		
1250	1270/1520	0,5	0,5	1250
	1270/1770	0,5		
	1270/2020	0,25		
	1270/2270	0,25		

Attention! When using dangerous respirable dust can occur. Do not breath in the dust! As of 24.08.2023 before an industrial or commercial application an according training has to be made.

#### **VENTAFLEX GmbH & Co. KG**

Siemensstraße 46 D-48341 Altenberge

Fon +49 (0) 2505 - 938290 Fax +49 (0) 2505 - 93829 -10

info@ventaflex.de www.ventaflex.de