



There are many different possibilities to connect an air duct to ventilation towers. This exemplary illustration shows the installation of the LAVANTUS® air duct to a ventilation tower by inserting it through a wall collar in the base plinth. (see installation instruction wall collar). In the example the ventilation tower is put on the protruding end of the air duct and attached to the base plinth.

Recommendation for cleaning

Ventilation systems must be inspected regularly to ensure hygiene, function and quality. The type and frequency of these inspections vary depending on individual circumstances. It is recommended that appropriate measures are carried out by a specialist company at least every 2 years.

For efficient cleaning, we recommend the use of brush robots with plastic brushes.

For stubborn soiling, we recommend MEZ CLEANER LM for cleaning and Sanosil S003 for disinfection. Both are cleaning and disinfecting agents for VENTAFLEX® air ducts and comply with the applicable safety standards. Please always read and follow the manufacturer's instructions for correct use.

VENTAFLEX GmbH & Co. KG
Siemensstraße 46
D-48341 Altenberge

Fon +49 25 05 – 93 829 0
Fax +49 25 05 – 93 829 - 10

info@ventaflex.de
www.ventaflex.de